
Incident Report

GEM Manufacturing, Inc.

From Date: Tuesday, February 6, 2007 12:00:00 AM
To Date: Tuesday, February 6, 2007 12:00:00 PM
Filtered By: Fire Extinguisher Tour
All Officers
All Incidents
Grouped By: Client, Facility, Group
Sorted By: Time

Main Offices

Fire Extinguisher Tour

GEM Manufacturing, Inc. • Main Offices • Fire Extinguisher Tour

| Date | Time | Officer | Location | Incident |
|-----------|-------|----------------|-------------------------|--------------------------------|
| 2/06/2007 | 09:15 | Danny Bosworth | 1001 - Plant North | Gauge is nominal (15 - 20 PSI) |
| | 09:34 | | 1002 - Plant North | Gauge is nominal (15 - 20 PSI) |
| | 09:52 | | 1003 - Plant West | Gauge is nominal (15 - 20 PSI) |
| | 10:15 | | 1004 - Plant West | Gauge is nominal (15 - 20 PSI) |
| | 10:23 | | 1005 - Solvents Storage | Spill Noted and Reported |
| | 10:34 | | 1006 - Administration | Gauge is nominal (15 - 20 PSI) |

Statistics for Fire Extinguisher Tour

Incident Reads: 6

Statistics for Main Offices

Incident Reads: 6

Statistics for Report

Incident Reads: 6

Incident Report

Shows the incidents in your patrol data. You can filter the data to show only incidents reported by specific officers, or at specific locations, or specific incidents, or by time.

