

Officer, Location, Incident Report for Fire Extinguisher Report

GEM Manufacturing, Inc.

1368 Edgewater Drive
 Cleveland, Ohio 44221
 Phone: (216) 555-1100
 Fax: (216) 555-1116

From Date: Tuesday, February 6, 2007 12:00:00 AM
 To Date: Tuesday, February 6, 2007 11:59:59 PM
 Filtered By: Fire Extinguisher Tour
 All Officers
 All Incidents
 Grouped By: Client, Facility, Group
 Sorted By: Time

Main Offices

1368 Edgewater Drive
 Cleveland, Ohio 44221
 Phone: (216) 555-1100
 Fax: (216) 555-1116

Fire Extinguisher Tour

GEM Manufacturing, Inc. • Main Offices • Fire Extinguisher Tour

Date	Time	Officer	Location	Incident
2/06/2007	08:41	Danny Bosworth		
2/06/2007	09:15		1001 - Plant North	
	09:15			Gauge is nominal (15 - 20 PSI)
	09:33		1002 - Plant North	
	09:34			Gauge is nominal (15 - 20 PSI)
	09:52		1003 - Plant West	
	09:52			Gauge is nominal (15 - 20 PSI)
	10:14		1004 - Plant West	
	10:15			Gauge is nominal (15 - 20 PSI)
	10:22		1005 - Solvents Storage	
	10:23			Spill Noted and Reported
	10:31		1006 - Administration	
	10:34			

Officer/Location/Incident Report

Shows officers, the locations they visited during their patrols, and any incidents reported. You can filter the data to show patrols made by specific officers, or specific locations visited, or specific incidents, or by time.

