

Officer Location Incident

Report Printed: Thursday, January 08, 2015 2:33 PM

From Date: Thursday, June 19, 2014 12:00 AM
To Date: Thursday, June 19, 2014 11:59 PM
Filtered By: Fire Extinguisher Tour
All Officers
All Incidents
Grouped By: Client, Facility, Group
Sorted By: Time

GEM Manufacturing, Inc.

Main Offices

Fire Extinguisher Tour

GEM Manufacturing, Inc. • Main Offices • Fire Extinguisher Tour

Date	Time	Officer	Location	Incident
6/19/2014	8:41 AM	Danny Bosworth		
	9:15 AM		1001 - Plant North	
	9:15 AM			Gauge is nominal (15 - 20 PSI)
	9:33 AM		1002 - Plant North	
	9:34 AM			Gauge is nominal (15 - 20 PSI)
	9:52 AM		1003 - Plant West	
	9:52 AM			Gauge is nominal (15 - 20 PSI)
	10:14 AM		1004 - Plant West	
	10:15 AM			Gauge is nominal (15 - 20 PSI)
	10:22 AM		1005 - Solvents Storage	
	10:23 AM			Gauge is nominal (15 - 20 PSI)
	10:31 AM		1006 - Administration	
	10:34 AM			Gauge is nominal (15 - 20 PSI)

Statistics for Fire Extinguisher Tour

Officer Reads: 1
Location Reads: 6
Incident Reads: 6
Total Button Reads: 13

Officer Location Incident Report

Shows Officers, the Locations they visited during their patrols, and any Incidents reported. You can filter the data to show patrols made by specific Officers, or specific Locations visited, or specific Incidents, or by time.