

Incidents

Report Printed: Thursday, January 08, 2015 2:14 PM

From Date: Thursday, June 19, 2014 12:00 AM
To Date: Thursday, June 19, 2014 11:59 PM
Filtered By: Fire Extinguisher Tour
All Officers
All Incidents
Grouped By: Client, Facility, Group
Sorted By: Time

GEM Manufacturing, Inc.

Main Offices

Fire Extinguisher Tour

GEM Manufacturing, Inc. • Main Offices • Fire Extinguisher Tour

Date	Time	Officer	Location	Incident
6/19/2014	9:15 AM	Danny Bosworth	1001 - Plant North	Gauge is nominal (15 - 20 PSI)
	9:34 AM		1002 - Plant North	Gauge is nominal (15 - 20 PSI)
	9:52 AM		1003 - Plant West	Gauge is nominal (15 - 20 PSI)
	10:15 AM		1004 - Plant West	Gauge is nominal (15 - 20 PSI)
	10:23 AM		1005 - Solvents Storage	Gauge is nominal (15 - 20 PSI)
	10:34 AM		1006 - Administration	Gauge is nominal (15 - 20 PSI)

Statistics for Fire Extinguisher Tour

Incident Reads: 6

Incident Report

Shows the Incidents in your patrol data. You can filter the data to show only Incidents reported by specific Officers, or at specific Locations, or specific Incidents, or by time.